



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

सचिव कार्यालय

Secretary Office

सेवा में / To,

✓ The Director

Fatehgarh III Beawar Transmission Limited,

Urjanidhi, 1, Barakhamba Lane,

Connaught Place,

New Delhi – 110001

विषय : विद्युत अधिनियम 2003, की धारा 68(1) के तहत Fatehgarh III Beawar Transmission Limited, जो PFC Consulting Limited (PFCCCL) की पूर्ण स्वामित्व वाली सहायक कंपनी है, को पारेषण योजना "Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part G" में शामिल शिरोपरि लाइन की स्थापना के लिये भारत सरकार का पूर्व अनुमोदन – सम्बंधित।

Subject: Prior approval of Government of India under Section 68(1) of the Electricity Act 2003, for installation of overhead transmission line under the transmission scheme "Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part G" to 'Fatehgarh III Beawar Transmission Limited', a wholly owned subsidiary of PFC Consulting Limited – reg.

संदर्भ/Reference: PFCCCL Online application ID SW8624267326-M029_D002_A003-1654075141926 dated dated 01.06.2022 on NSWS portal and subsequent clarification submitted on 30.09.2022.

महोदय/Sir,

Reference is invited to the above mentioned application, seeking prior approval of Government of India under Section 68 (1) of the Electricity Act 2003, for the installation of the overhead transmission line under the transmission scheme "Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part G" in favor of the SPV, 'Fatehgarh III Beawar Transmission Limited' (who shall own the transmission scheme project and the transmission license shall be issued in its favour), with the following scope of works:

(R)
राकेश गोयल / RAKESH GOYAL
सचिव / Secretary
केन्द्रीय विद्युत प्राधिकरण / C.E.A.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Govt. of India
नई दिल्ली / New Delhi-66

| Sl. No. | Scope of the Transmission Scheme | Capacity /km |
|---------|---|--|
| 1. | Fatehgarh-3– Beawar 765 kV D/c (2 nd) along with 330 MVAR Switchable line reactor for each circuit at each end of Fatehgarh-3– Beawar 765 kV D/c line | Length – 350 km Switching equipment for 765 kV 330 MVAR switchable line reactor –4 765 kV, 330 MVAR Switchable line reactor- 4 |
| 2 | 2 nos. of 765kV line bays both at Beawar & Fatehgarh-3 | 765 kV line bays – 4 nos. |

Note:

- Developer of Fatehgarh-3 S/s to provide space for 2 nos. of 765 kV line bays at Fatehgarh-3 S/s along with space for 765 switchable line reactors.
- Developer of Beawar S/s to provide space for 2 nos. of 765 kV line bays at Beawar S/s along with space for 765kV switchable line reactors.
- The line lengths mentioned above are approximate as the exact length shall be obtained after the detailed survey.

2. Ministry of Power vide Gazette notification no. 4661 dated 06.12.2021 has appointed PFC Consulting Limited (PFCCCL) as Bid Process Coordinator for the purpose of selection of Bidder as Transmission Service Provider (TSP) to establish the transmission scheme “Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part G” to be implemented through tariff based competitive bidding route. PFC Consulting Limited, the Bid Process Coordinator, has incorporated the SPV, ‘Fatehgarh III Beawar Transmission Limited’, for the implementation of the scheme.

3. Considering the above, CEA conveys prior approval of Government under Section 68(1) of Electricity Act 2003, to the SPV, ‘Fatehgarh III Beawar Transmission Limited’, for installation of the following overhead transmission line under the transmission scheme “Transmission system for evacuation of power from REZ in Rajasthan (20 GW) under Phase-III Part G”:

- Fatehgarh-3 – Beawar 765 kV D/c (2nd) line

4. If the route of the above mentioned transmission lines falls in the GIB potential Zone (marked in the map which is part of the Hon’ble Supreme Court order dated 19.04.2021, in the petition No. 838 of 2019), the Transmission Service Provider implementing the above mentioned transmission scheme shall comply with the decision of Hon’ble Supreme Court of India in its Order in I.A. No. 85618 of 2020 dated 19.04.2021 in Writ Petition No. 838 of 2019 for laying of overhead transmission lines.

5. This approval is subject to compliance of:

- The relevant provisions of the Electricity Act 2003, as amended from time to time and the rules and regulations made thereunder,



राकेश गोयल / RAKESH GOYAL
सचिव / Secretary
केन्द्रीय विद्युत प्राधिकरण / C.E.A.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Govt. of India

- (ii) CEA (Measures relating to Safety and Electrical Supply) Regulations 2010, and any subsequent amendments made thereto, and
- (iii) The decision of Hon'ble Supreme Court of India in its Order in I.A. No. 85618 of 2020 dated 19.04.2021 in Writ Petition No. 838 of 2019 for laying of overhead transmission lines.
6. The approval is also subject to the following conditions:
- (i) The implementing agency will commence construction of the transmission line mentioned at para 3 above within three years of grant of approval, unless this term is extended by the Central Electricity Authority.
- (ii) Central Electricity Authority may withdraw the approval before the expiry of the period of three years after giving a one-month notice.
- (iii) The implementing agencies shall abide by the provisions of Works of Licensee Rules, 2006 notified by the Govt. of India, Ministry of Power in the Gazette of India, extraordinary Part-II, Section 3(i) dated 18-04-2006 (vide GSR 217 (E) dated 18-04-2006).

भवदीय / Yours faithfully,



(राकेश गोयल / Rakesh Goyal)

सचिव / Secretary, के.वि.प्रा / CEA

राकेश गोयल / RAKESH GOYAL
सचिव / Secretary
केन्द्रीय विद्युत प्राधिकरण / C.E.A.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Govt. of India
नई दिल्ली / New Delhi-66

प्रतिलिपि / Copy to -

Joint Secretary (Trans), Ministry of Power, Shram Shakti Bhawan, New Delhi